



NOTES:

1. ADDITIONAL DISCHARGES THROUGH THE POWERHOUSE WILL RANGE BETWEEN 550 AND 780 CFS.
2. MAXIMUM RESERVOIR ELEVATION AT WHICH POWERHOUSE WILL BE OPERATED IS ELEV. 440 FT. N.G.V.D.(50 FT. STAGE)
3. RATING CURVE DATA PREPARED BY V.E.C.

INVERT ELEV. = 390 FT. NGVD
 SPILLWAY ELEV. = 546.5 (156.5 FT. STAGE)
 D/S FLOOD CONTROL OPENING: 8'-4" WIDE x 12' HIGH

WATER RESOURCES DEVELOPMENT PROJECT
 CONNECTICUT RIVER BASIN
 NORTH HARTLAND LAKE
DISCHARGE RATING CURVES
 BYPASS CONTROL GATE
 DURING HYDRO GENERATION
 NEW ENGLAND DIVISION WALTHAM, MASS.
 MARCH 1985